

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				CR116		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner FAHERTY @ SON WELL DRILLING						Phone # (608)348-8000		1. Well Location				Fire # (if avail.)									
Mailing Address PO BOX 247						City of PLATTEVILLE						Street Address or Road Name and Number									
City PLATTEVILLE						State WI		Zip Code 53818				600 E HWY 151									
County Grant		Co. Permit #		Notification #		Completed 08-12-1989		Subdivision Name				Lot #		Block #							
Well Constructor (Business Name) FAHERTY DRILLING COMPANY INC				Lic. # 616		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 42.72974 °N -90.46873 °W				Method Code GCD005							
Address P O BOX 247 PLATTEVILLE WI 53818				Well Plan Approval #				NE SE		Section 15		Township 3 N		Range 1 W							
				Approval Date (mm-dd-yyyy)				or Govt Lot #													
Hicap Permanent Well #				Common Well #		Specific Capacity 2.9				2. Well Type New Well				of previous unique well #		constructed in					
Reason for replaced or reconstructed well ? NEW SHOP																					
3. Well serves # of SHOP						Hicap Well ? No				Construction Type Drilled											
Private, potable						Hicap Property ? No															
Heat Exchange ___ # of drillholes						Hicap Potable ?															
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
10		Surface		40		Rotary - Mud Circulation						C		CLAY		Surface		7			
6		40		115		<u>Yes</u> Rotary - Air						L		GALENA LIMESTONE		7		81			
						Rotary - Air & Foam						L		UPPER PLATTEVILLE		81		115			
						Drill-Through Casing Hammer															
						Reverse Rotary															
						Cable-tool Bit ___ in. dia...															
						Dual Rotary															
						Temp. Outer Casing ___ in. dia															
						Removed? ___ depth ft. (If NO explain on back side)															
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		58 ft. below ground surface				12 in. above grade							
6		A-53-B 19.45/FT. VALLEY STEEL T@C				Surface		40		10. Pump Test				Developed ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 65 ft. below surface				Disinfected ? Yes							
										Pumping at 20 GP for 0.5 Hrs.				Capped ? Yes							
										Pumping Method ?											
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?							
Method PRES. PUMPED														Filled & Sealed Well(s) as needed?							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		13. Constructor / Supervisory Driller				Lic #		Date Signed					
PORTLAND TYPE 1				Surface		40		8		FF						08-13-1989					
										Drill Rig Operator				Lic or Reg #		Date Signed					
										FF						08-13-1989					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		35	Building Overhang		70
			Sewer - Building Sanitary		60

Comment:

Created On: 12-08-1989

Updated On: 07-12-2021

Review Status: