Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CR364

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ALAN L GRUBA	Phone #: (715)877-2825
Mailing Address: RT 1 BOX 248	
City: FALL CREEK	State: WI Zip Code: 54742
County: Eau Claire	Co. Permit #: W05565
Notification #	Completed: 12-19-1990
Well Constructor (Business Name): HATFIELD JOHN J	Lic. #: 4934
Facility ID # (Public Wells)	
Well Plan Approval #	
Address: RT 2 STANLEY WI 54768	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #
Specific Capacity: 0.6	

1. Well Location

Town of LINCOLN	Fire # (if avail.): 1010
Street Address or Road Name and Number: RT 1 BOX 248	
Subdivision Name	Lot # / Block #
Latitude / Longitude in Decimal Degree (DD) °N °W	Method Code
NW SE or Govt Lot #:	Section: 9 Township: 26 N Range: 7 W

2. Well Type Replacement

of previous unique well # constructed in

Reason for replaced or reconstructed well ?: OLD WELL HAS ATRIZINE IN

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	41
6	41	99

Upper Enlarged Drillhole / Lower Open Bedrock

Yes Rotary - Mud Circulation .....

Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
C	CLAY	Surface	12
N	SAND ROCK	12	99

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STD. BLACK STEEL WELDED PLAIN END .280 WALL 19:49ASTM-A-53 H.K.K. SAWHILL	Surface	45
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

30 ft. below ground surface

10. Pump Test

Pumping level 70 ft. below surface

Pumping at 25 GP for 1 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method PIPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CEMENT GROUT	Surface	41	15

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

JEFF HATFIELD WILL DO LATER

13. Constructor / Supervisory Driller	Lic #	Date Signed
JJH		12-24-1990
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		105
Building Overhang		17

Type	Qualifier	Distance
Sewer - Building Sanitary		80
Septic or Holding, or POWTS Tank		95

Comment:

Created On: 07-17-1991 Updated On: 07-17-1991 Review Status: