Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CR720

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: DON HUART	Phone #: (414)279-6606
Mailing Address: RT 1 BOX 173	
City: GENOA CITY	State: WI — Zip Code: 53128
County: Kenosha	Co. Permit #: — Notification #: — Completed: 12-19-1990
Well Constructor (Business Name): JOHNSON HUBERT R	Lic. #: 626 — Facility ID # (Public Wells):
Address: RT 2 BOX 110 GENOA CITY WI 53128	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 2

1. Well Location

Fire # (if avail.):

Town of RANDALL

Street Address or Road Name and Number: 40220 91ST ST

Subdivision Name	Lot #	Block #
JEFFERSON ISLAND		

Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:

NE SW or Govt Lot #	Section	Township	Range
	18	1 N	19 E

2. Well Type Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: SLOW PRODUCING POINT

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	20

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 10in. dia...
- Dual Rotary .....
- Yes — Temp. Outer Casing 10in. dia
- Yes — Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T		S	G	BRN SAND GRAVEL	Surface	18
G		C		GRAY CLAY	18	26
T		S	G	BRN SAND GRAVEL	26	37

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5.6	A53 T@C 15# PER FT VALLEY STEEL	Surface	34
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	SS WIRE WRAP	34	37

9. Static Water Level

15 ft. below ground surface

10. Pump Test

Pumping level 20 ft. below surface

Pumping at 10 GP for 24 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CLAY DRILL MUD	Surface	20	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
HJ		12-22-1990
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		70

Type	Qualifier	Distance
Building Overhang		15
Septic or Holding, or POWTS Tank		60

Comment:

Created On: 03-25-1991 Updated On: 10-24-2002 Review Status: