Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CS093

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: JIM MUNRO			Phone #
Mailing Address: 6656 WOODRIDGE			
City: JANESVILLE	State: WI	Zip Code: 53545	
County: Rock	Co. Permit #	Notification #	Completed: 03-15-1991

1. Well Location

Town of CENTER

Fire # (if avail.)

Street Address or Road Name and Number: 6656 WOODRIDGE

Subdivision Name	Lot #	Block #
WOODRIDGE EST.		

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
GOVERT WALTER AND LEON	658	

Latitude / Longitude in Decimal Degree (DD): 42.7433 °N -89.1337 °W

Method Code: GCD013

NE	NE	Section	Township	Range
or Govt Lot #		12	3 N	11 E

Address: RT 2 BOX 98, BELOIT WI 53511

Well Plan Approval #

Approval Date (mm-dd-yyyy)

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?: NEW HOME

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.7

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	130

Upper Enlarged Drillhole / Lower Open Bedrock

Yes Rotary - Mud Circulation .....

Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C		CLAY	Surface	12
		C	G	CLAY @ COARSE GRAVEL	12	110
		S	G	SAND @ GRAVEL	110	130

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	A53 S.40 P.E. STEEL 18.97# VENEZUELA	Surface	126
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	S.S. SCREEN .025 SLOT	126	130

9. Static Water Level

90 ft. below ground surface

10. Pump Test

Pumping level 105 ft. below surface

Pumping at 10 GP for 4 Hrs.

Pumping Method ?

11. Well Is

13 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILL MUD @ CUTTINGS	Surface	126	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
WG		03-26-1991
Drill Rig Operator	Lic or Reg #	Date Signed
MG		03-26-1991

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		70
Building Drain - Sanitary		20

Type	Qualifier	Distance
Building Overhang		2040
Sewer - Building Sanitary		25

Comment:

Created On: 07-12-1991 Updated On: 12-09-2019 Review Status: