Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CS829

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SCHAUDER BUILDING, INC.		Phone #: (608)754-8006
Mailing Address: 4115 HWY 51 N		
City: JANESVILLE	State: WI	Zip Code: 53545

County	Co. Permit #	Notification #	Completed
Walworth			01-23-1992

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
CHENEY, JAMES E	339	

Address: RT 4 BOX 472
ELKHORN WI 53121-9470

Well Plan Approval #:

Approval Date (mm-dd-yyyy):

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.2

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of DELAVAN

Fire # (if avail.)

Street Address or Road Name and Number

Subdivision Name	Lot #	Block #
WOODLAWN BAY	00003	2

Latitude / Longitude in Decimal Degree (DD) °N °W

Method Code

NW or Govt Lot #	NE	Section	Township	Range
		21	2 N	16 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	20
5	20	92

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 5in. dia...
- Dual Rotary .....
- Yes — Temp. Outer Casing 10in. dia
- Yes — Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
C	PUDDLE CLAY	Surface	30
X	SAND @ CLAY	30	40
S	SAND	40	48
C	CLAY	48	88
Y	SAND @ GRAVEL	88	92

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	P/E NEW BLK STEELK 5 9/16 ODX.258 WALL 14:62 LB.TYPE EW VSPCO B ASTM-A53 B HYDRO TESTED 1950 PSI	Surface	88
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	STAINLESS STEEL SCREEN	88	92

7. Grout or Other Sealing Material

Method GROUTING

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
PUDDLE CLAY	Surface	20	

9. Static Water Level
42 ft. below ground surface

10. Pump Test
Pumping level 77 ft. below surface
Pumping at 8 GP for 8 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
JEC		01-24-1992
Drill Rig Operator	Lic or Reg #	Date Signed
JDC		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang	>	8	Collector Sewer - San or Storm		140

Comment:

Created On: 06-01-1992 Updated On: 06-01-1992 Review Status: