

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				CT195		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner DAVID GROSS						Phone # () 529-1800		1. Well Location				Fire # (if avail.)					
Mailing Address 266 D CONY AVE						Town of DELAFIELD						Street Address or Road Name and Number S14 W32965 FOREST HILLS RD					
City DOUSMAN				State WI		Zip Code 53718											
County Waukesha		Co. Permit #		Notification #		Completed 12-05-1990		Subdivision Name				Lot #		Block #			
Well Constructor (Business Name) BURGARINO EMANUEL				Lic. # 512		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)				Method Code			
Address 809 S 85TH ST WEST ALLIS WI 53214				Well Plan Approval #				SW NE Section Township Range or Govt Lot # 5 6 N 18 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled							
				Approval Date (mm-dd-yyyy)													
Hicap Permanent Well #				Common Well #		Specific Capacity 0.7				3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes Hicap Well ? No Hicap Property ? No Hicap Potable ?							
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.) 8.75		From (ft.) Surface		To (ft.) 83		Upper Enlarged Drillhole Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
Yes Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)						G S		GRAVEL @ SAND		Surface		83					
6. Casing, Liner, Screen						8. Geology				11. Well Is 12 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)						9. Static Water Level 41 ft. below ground surface			
6		PE NEW STEEL 18.97# PER FT ASTM A 53 GRADEB LTV				Surface		83						10. Pump Test Pumping level 60 ft. below surface Pumping at 14 GP for 4 Hrs. Pumping Method ?			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? Yes							
7. Grout or Other Sealing Material																	
Method																	
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement									
DRILLING MUD				Surface		83		13. Constructor / Supervisory Driller				Lic #		Date Signed			
EB				Drill Rig Operator				Lic or Reg #				02-12-1991					
												Date Signed					
												02-12-1991					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		17

Comment:

Created On: 07-17-1991

Updated On: 07-17-1991

Review Status: