Well Construction Report
WISCONSIN UNIQUE WELL NUMBER: CT195

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: DAVID GROSS	Phone #: ( )529-1800
Mailing Address: 266 D CONY AVE	
City: DOUSMAN	State: WI — Zip Code: 53718
County: Waukesha	Co. Permit #: — Notification #: — Completed: 12-05-1990
Well Constructor (Business Name): BURGARINO EMANUEL	Lic. #: 512 — Facility ID # (Public Wells):
Address: 809 S 85TH ST, WEST ALLIS WI 53214	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.7

1. Well Location

Town of DELAFIELD

Fire # (if avail.):

Street Address or Road Name and Number: S14 W32965 FOREST HILLS RD

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:

SW	NE	Section	Township	Range
or Govt Lot #		5	6 N	18 E

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	83

Upper Enlarged Drillhole — Lower Open Bedrock

Yes — Rotary - Mud Circulation .....

Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		G	S	GRAVEL @ SAND	Surface	83

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	PE NEW STEEL 18.97# PER FT ASTM A 53 GRADEB LTV	Surface	83
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

41 ft. below ground surface

10. Pump Test

Pumping level 60 ft. below surface

Pumping at 14 GP for 4 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILLING MUD	Surface	83	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
EB		02-12-1991
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
EB		02-12-1991

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		17

Comment:

Created On: 07-17-1991 Updated On: 07-17-1991 Review Status: