Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CT402

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: DANIEL BENNETT	Phone #: ( )764-5985
Mailing Address: S83 W32936 OAK TREE	
City: MUKWONAGO	State: WI — Zip Code: 53149
County: Waukesha	Co. Permit #: — Notification #: — Completed: 12-15-1991
Well Constructor (Business Name): BURGARINO EMANUEL	Lic. #: 512 — Facility ID # (Public Wells):
Address: 809 S 85TH ST, WEST ALLIS WI 53214	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.6

1. Well Location

City of MUKWANAGO

Fire # (if avail.):

Street Address or Road Name and Number: S83 W32936 S OAK TREE CT

Subdivision Name	Lot #	Block #
COUNTY BLISS	00030	

Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:

NW SW or Govt Lot #	Section	Township	Range
	17	5 N	18 E

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	75
6	75	110

Upper Enlarged Drillhole — Lower Open Bedrock

Yes — Rotary - Mud Circulation .....

Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
G	GRAVEL	Surface	55
P	HARD PAN	55	75
L	LIMESTONE	75	110

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	P.E. NEW STEEL 18.97# PER FT ASTM-A-53 GRADE-B-LTV	Surface	75
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

41 ft. below ground surface

10. Pump Test

Pumping level 65 ft. below surface

Pumping at 15 GP for 8 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILLING MUD	Surface	75	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
EB		03-04-1991
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
EB		03-04-1991

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		12

Comment:

Created On: 07-16-1991 Updated On: 07-16-1991 Review Status: