

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				CT405		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner CONSTRUCTION MANAG.						Phone # () 544-9275		1. Well Location				Fire # (if avail.)							
Mailing Address 2315 BADGEN DR						Town of DELAFIELD						Street Address or Road Name and Number W328 S1422 FORREST HILLS CT							
City WAUKESHA				State WI		Zip Code 53188													
County Waukesha		Co. Permit #		Notification #		Completed 12-15-1991		Subdivision Name				Lot #		Block #					
Well Constructor (Business Name) BURGARINO EMANUEL				Lic. # 512		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code							
Address 809 S 85TH ST WEST ALLIS WI 53214				Well Plan Approval #		NW NW Section Township Range or Govt Lot # 5 6 N 18 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled											
				Approval Date (mm-dd-yyyy)															
Hicap Permanent Well #		Common Well #		Specific Capacity 0.3		3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes													
Hicap Well ? No Hicap Property ? No Hicap Potable ?																			
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock						Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)						
8.75 Surface 83			Yes Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)						G GRAVEL		Surface 55								
6 83 175									P HARD PAN		55 83								
									L LIMESTONE		83 175								
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) To (ft.)		52 ft. below ground surface				12 in. above grade							
6		P.E. NEW STEEL 18.97# PER FT ASTM-A-53 GRADE B-LTV				Surface 83		10. Pump Test Pumping level 110 ft. below surface Pumping at 15 GP for 4.5 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.) To (ft.)													
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? Yes							
Method																			
Kind of Sealing Material		From (ft.) To (ft.) # Sacks Cement		DRILLING MUD Surface 83															
												13. Constructor / Supervisory Driller				Lic #		Date Signed	
												EB						03-14-1991	
												Drill Rig Operator				Lic or Reg #		Date Signed	
												EB						03-14-1991	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		14

Comment:

Created On: 07-16-1991

Updated On: 02-23-2018

Review Status: