Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CT556

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: HECKEL			Phone #
Mailing Address: 147 GRESHEL LN			
City: MT PLEASANT	State: WI	Zip Code: 53177	
County: Racine	Co. Permit #	Notification #	Completed: 10-25-1990

1. Well Location

Village of MT PLEASANT

Fire # (if avail.)

Street Address or Road Name and Number

Subdivision Name	Lot #	Block #

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
HARTMAN, STEVE	324	

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code

Well Plan Approval #

SE	SE	Section	Township	Range
or Govt Lot #		10	3 N	22 E

Address: S87 W22625 EDGEWOOD
BIG BEND WI 53103

Approval Date (mm-dd-yyyy)

2. Well Type New Well

of previous unique well # constructed in

Hicap Permanent Well #	Common Well #	Specific Capacity
		3

Reason for replaced or reconstructed well ?

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	20
6	20	125

Upper Enlarged Drillhole / Lower Open Bedrock

Yes — Rotary - Air .....

Rotary - Mud Circulation .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C		CLAY	Surface	87
		P		HARD PAN	87	110
		L		LIME STONE	110	125

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK P.E. ASTM A53-B 19# SAWHILL STEEL	Surface	110
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

20 ft. below ground surface

10. Pump Test

Pumping level 25 ft. below surface

Pumping at 15 GP for 10 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CLAY SLURRY	Surface	20	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
		10-25-1990
Drill Rig Operator	Lic or Reg #	Date Signed
SLH		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		20	Collector Sewer - San or Storm		75
Clearwater Sump		35	Sewer - Building Sanitary		50

Comment:

Created On: 04-24-1992 Updated On: 04-24-1992 Review Status: