Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CT584

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: TOM JURAN			Phone #
Mailing Address: 27420 FOXHAVEN DR			
City: WIND LAKE	State: WI	Zip Code: 53185	
County: Racine	Co. Permit #	Notification #	Completed: 06-10-1991

Well Constructor (Business Name): HARTMAN, STEVE	Lic. #: 324	Facility ID # (Public Wells)	
Address: S87 W22625 EDGEWOOD BIG BEND WI 53103		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 2	

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of NORWAY

Fire # (if avail.)

Street Address or Road Name and Number: 27420 FOXHAVEN DR

Subdivision Name: WISPERING HILLS	Lot #: 00019	Block #

Latitude / Longitude in Decimal Degree (DD): 42.8179 °N -88.1761 °W
Method Code: GCD013

SW SE or Govt Lot #	Section: 7	Township: 4 N	Range: 20 E

2. Well Type New Well — HO738 replaces this well
of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	37

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
G	GRAVEL	Surface	37

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK P.E. ASTM A53-B 19# SAWHILL	Surface	37
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material
Method

9. Static Water Level
15 ft. below ground surface

10. Pump Test
Pumping level 20 ft. below surface
Pumping at 10 GP for 12 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
SH		06-10-1991
Drill Rig Operator	Lic or Reg #	Date Signed
SH		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		15	Collector Sewer - San or Storm		60
Clearwater Sump		25	Downspout/Yard Hydrant		20
			Sewer - Building Sanitary		15

Comment:

Created On: 04-27-1992 Updated On: 07-11-2023 Review Status: