Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CT612

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: DEAN ZERKOWSKI			Phone #: (414)895-2603
Mailing Address: 26448 @ 26450 KENDRA			
City: WIND LAKE	State: WI	Zip Code: 53185	
County: Racine	Co. Permit #:	Notification #:	Completed: 01-23-1992

Well Constructor (Business Name): HARTMAN, STEVE	Lic. #: 324	Facility ID # (Public Wells):	
Address: S87 W22625 EDGEWOOD BIG BEND WI 53103		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.7	

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Village of WIND LAKE

Fire # (if avail.)

Street Address or Road Name and Number
26448 @ 50 KENDRA LN

Subdivision Name: WOODBURY ESTATES	Lot #: 00014	Block #:

Latitude / Longitude in Decimal Degree (DD)
°N °W

Method Code

or Govt Lot # 003	Section: 8	Township: 4 N	Range: 20 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
WATER

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	20
6	20	265

Upper Enlarged Drillhole — Lower Open Bedrock

Yes Rotary - Air .....
Rotary - Mud Circulation .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C		CLAY	Surface	140
		S		SAND	140	158
		C		CLAY	158	180
	B	L		BROKEN LIMESKTONE	180	207
		L		LIMESTONE	207	212
R		L		RED LIMESTONE	212	220
G		L		GRAY LIMESTONE	220	241
		L		LIMESTONE	241	265

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK P.E. ASTM A53-B 19# SAWHILL STEEL	Surface	207
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
45 ft. below ground surface

10. Pump Test
Pumping level 60 ft. below surface
Pumping at 10 GP for 18 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method GRAVITY

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CLAY SLURRY	Surface	20	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
SH		01-23-1992
Drill Rig Operator	Lic or Reg #	Date Signed
SH		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		40	Collector Sewer - San or Storm		58
Building Overhang		15	Downspout/Yard Hydrant		15
Clearwater Sump		40	Sewer - Building Sanitary		12

Comment:

Created On: 06-01-1992 Updated On: 06-01-1992 Review Status: