

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				CT612		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner DEAN ZERKOWSKI						Phone # (414)895-2603		1. Well Location				Fire # (if avail.)			
Mailing Address 26448 @ 26450 KENDRA						Village of WIND LAKE						Street Address or Road Name and Number 26448 @ 50 KENDRA LN			
City WIND LAKE				State WI		Zip Code 53185									
County Racine		Co. Permit #		Notification #		Completed 01-23-1992		Subdivision Name WOODBURY ESTATES				Lot # 00014		Block #	
Well Constructor (Business Name) HARTMAN, STEVE				Lic. # 324		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code			
Address S87 W22625 EDGEWOOD BIG BEND WI 53103				Well Plan Approval #		or Govt Lot # 003		Section 8		Township 4 N		Range 20 E			
				Approval Date (mm-dd-yyyy)		2. Well Type New Well									
Hicap Permanent Well #		Common Well #		Specific Capacity 0.7		of previous unique well # constructed in									
3. Well serves 1 # of HOME				Hicap Well ? No		Reason for replaced or reconstructed well ?									
Private, potable				Hicap Property ? No		WATER									
Heat Exchange ___ # of drillholes				Hicap Potable ?		Construction Type Drilled									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology					
10		Surface		20		Rotary - Mud Circulation		Rotary - Air		Rotary - Air & Foam					
6		20		265		Drill-Through Casing Hammer		Reverse Rotary		Cable-tool Bit ___ in. dia...					
6		20		265		Dual Rotary		Temp. Outer Casing ___ in. dia		Removed? ___ depth ft. (If NO explain on back side)					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level					
6		NEW BLACK P.E. ASTM A53-B 19# SAWHILL STEEL				Surface		207		45 ft. below ground surface					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		11. Well Is					
6		NEW BLACK P.E. ASTM A53-B 19# SAWHILL STEEL				Surface		207		12 in. above grade					
7. Grout or Other Sealing Material															
Method GRAVITY															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Developed ? Yes					
CLAY SLURRY				Surface		20		20		Disinfected ? Yes					
8. Geology															
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)		Capped ? Yes					
C		CLAY				Surface		140		158					
S		SAND				140		158		180					
C		CLAY				158		180		207					
B L		BROKEN LIMESKTONE				180		207		212					
L		LIMESTONE				207		212		220					
R L		RED LIMESTONE				212		220		241					
G L		GRAY LIMESTONE				220		241		265					
L		LIMESTONE				241		265		265					
10. Pump Test															
Pumping level 60 ft. below surface															
Pumping at 10 GP for 18 Hrs.															
Pumping Method ?															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed? No															
13. Constructor / Supervisory Driller															
SH				Lic #				Date Signed							
SH				01-23-1992				01-23-1992							
Drill Rig Operator															
SH				Lic or Reg #				Date Signed							
SH				01-23-1992				01-23-1992							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		40	Collector Sewer - San or Storm		58
Building Overhang		15	Downspout/Yard Hydrant		15
Clearwater Sump		40	Sewer - Building Sanitary		12

Comment:

Created On: 06-01-1992

Updated On: 06-01-1992

Review Status: