Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CU105

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: GEORGE SCHUBERT			Phone #
Mailing Address: 1225 S EUCLID AVE			
City: BERWYN	State: IL	Zip Code: 60402	
County: Marquette	Co. Permit #	Notification #	Completed: 07-05-1991
Well Constructor (Business Name): DAVIS, FLOYD	Lic. #: 678	Facility ID # (Public Wells)	
Address: RT 3 BOX 644 MONTELLO WI 53949-9378		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 5	

1. Well Location

Town of PACKWAUKEE

Fire # (if avail.)

Street Address or Road Name and Number

Subdivision Name	Lot #	Block #
MARQUETTE MEADOWS		

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code

NE	SW	Section	Township	Range
or Govt Lot #		29	15 N	9 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	34
4	34	84

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 10in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C		CLAY	Surface	34
		S		SAND	34	44
		P		HARD PAN	44	71
	N	S		FINE SAND	71	80
		G	S	GRAVEL @ SAND	80	84

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	IN NEW BLACK STEEL T@C ASTM A53 11# PER FT. 2210PSI VSPCO	Surface	80
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	STAINLESS STEEL (6 FT.)	80	84

7. Grout or Other Sealing Material

Method PUMP

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
PUDDLED CLAY	Surface	34	

9. Static Water Level

37 ft. below ground surface

10. Pump Test

Pumping level 41 ft. below surface

Pumping at 20 GP for 1 Hrs.

Pumping Method ?

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
FD		04-14-1992
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		63

Type	Qualifier	Distance
Building Overhang	>	13
Septic or Holding, or POWTS Tank		53

Comment:

Created On: 06-09-1992 Updated On: 06-09-1992 Review Status: