

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				CU644		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner KARL SCHMIDT						Phone # (715)258-2730		1. Well Location				Fire # (if avail.) N3834	
Mailing Address N3834 MORGAN DR						Town of FARMINGTON						Street Address or Road Name and Number MORGAN DR	
City WAUPACA			State WI		Zip Code 54981		Subdivision Name				Lot # Block #		
County Waupaca		Co. Permit #		Notification #		Completed 10-13-1990		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code	
Well Constructor (Business Name) JOHNSON STANLEY				Lic. # 189		Facility ID # (Public Wells)		NW SW Section Township Range or Govt Lot # 17 22 N 11 E		Well Plan Approval #			
Address E 1480 RURAL ROAD WAUPACA WI 54981				Approval Date (mm-dd-yyyy)		2. Well Type New Well							
Hicap Permanent Well #		Common Well #		Specific Capacity 3		Reason for replaced or reconstructed well ?							
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.) 10		From (ft.) Surface		To (ft.) 20		Upper Enlarged Drillhole Lower Open Bedrock Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary <u>Yes</u> Temp. Outer Casing 10in. dia <u>Yes</u> Removed? ___ depth ft. (If NO explain on back side)							
8. Geology													
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
S G		SAND AND GRAVEL				Surface		20					
P G		HARDPAN AND BOLDERS				20		40					
G		GRAVEL				40		50					
S G		SAND AND GRAVEL				50		62					
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
5		15 LBS BLACK STEEL 1200 LBS. TEST ASTM A120 VSP COT AND C				Surface		59					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
4		STAINLESS STEEL				59		62					
7. Grout or Other Sealing Material													
Method													
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement							
CLAY SLURRY		Surface		7		20							
9. Static Water Level													
40 ft. below ground surface													
10. Pump Test													
Pumping level 44 ft. below surface													
Pumping at 12 GP for 1 Hrs.													
Pumping Method ?													
11. Well Is													
10 in. above grade													
Developed ? Yes													
Disinfected ? Yes													
Capped ? Yes													
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed?													
13. Constructor / Supervisory Driller													
Lic #		Date Signed											
SJ		10-15-1990											
Drill Rig Operator													
Lic or Reg #		Date Signed											
SJ		10-15-1990											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		55	Building Overhang		5
			Septic or Holding, or POWTS Tank		35

Comment:

Created On: 07-17-1991

Updated On: 07-17-1991

Review Status: