Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CU648

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: IRV HAJEK	Phone #: (715)258-0171
Mailing Address: N2707 PRYSE DR	
City: WAUPACA	State: WI — Zip Code: 54981
County: Waupaca	Co. Permit #: — Notification #: — Completed: 10-20-1990
Well Constructor (Business Name): JOHNSON STANLEY	Lic. #: 189 — Facility ID # (Public Wells):
Address: E 1480 RURAL ROAD WAUPACA WI 54981	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 1.5

1. Well Location

Town of FARMINGTON	Fire # (if avail.): N2707
Street Address or Road Name and Number: N2707 PRYSE DR	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): °N °W	Method Code:
or Govt Lot #: — NW — Section: 36 — Township: 22 N — Range: 11 E	

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	20

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....

Yes Temp. Outer Casing 10in. dia
Yes Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
S	SAND	Surface	118

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	15 LBS BLACK STEEL 1200 LBS TEST ASTM A120 ASTMA120 VSP CO T@C	Surface	115
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	STAINLESS STEEL	115	118

9. Static Water Level
28 ft. below ground surface

10. Pump Test
Pumping level 36 ft. below surface
Pumping at 12 GP for 1 Hrs.
Pumping Method ?

11. Well Is
10 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CLAY SLURRY	Surface	20	

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
SJ		10-25-1990
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
SJ		10-25-1990

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		55

Type	Qualifier	Distance
Building Overhang		8
Septic or Holding, or POWTS Tank		35

Comment:

Created On: 07-15-1991 Updated On: 07-15-1991 Review Status: