

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				CU649		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner HENRY HAARTH Phone # (715)366-2434						1. Well Location				Fire # (if avail.)							
Mailing Address 9826 OAKDALE DR						Town of LANARK				9826							
City ALMOND State WI Zip Code 54909						Street Address or Road Name and Number 9826 OAKDALE DR											
County		Co. Permit #		Notification #		Completed		Subdivision Name		Lot #		Block #					
Portage						10-30-1990											
Well Constructor (Business Name)				Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code					
JOHNSON STANLEY				189				44.3366 °N -89.2917 °W				GCD013					
Address E 1480 RURAL ROAD WAUPACA WI 54981				Well Plan Approval #		SW NE Section Township Range		33 22 N 10 E									
				Approval Date (mm-dd-yyyy)													
Hicap Permanent Well #				Common Well #		Specific Capacity		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled									
						0.4											
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
10		Surface		20						S G		SAND AND GRAVEL		Surface		30	
						Rotary - Mud Circulation				C G		CLAY AND GRAVEL		30		50	
						Rotary - Air				S C		STICKY SAND		50		65	
						Rotary - Air & Foam				P		HARD PAN		65		80	
						Drill-Through Casing Hammer				S G		SAND AND GRAVEL		80		116	
						Reverse Rotary											
						Cable-tool Bit ___ in. dia...											
						Dual Rotary											
						<u>Yes</u> Temp. Outer Casing 10in. dia <u>Yes</u> Removed? ___ depth ft. (If NO explain on back side)											
6. Casing, Liner, Screen												8. Geology					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level 75 ft. below ground surface				11. Well Is 10 in. above grade			
6		BLACK STEEL 19.45 LBS PER FT A53 VSP CO T AND C				Surface		113		10. Pump Test Pumping level 100 ft. below surface Pumping at 10 GP for 1 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
6		STAINLESS STEEL				113		116									
7. Grout or Other Sealing Material Method												12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?					
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		13. Constructor / Supervisory Driller				Lic #		Date Signed	
QUIK GEL				Surface		7		20		SJ						11-03-1990	
										Drill Rig Operator				Lic or Reg #		Date Signed	
										SJ						11-03-1990	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60	Building Overhang		10
			Septic or Holding, or POWTS Tank		50

Comment:

Created On: 07-17-1991

Updated On: 05-07-2020

Review Status: