Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CU685

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: DAVID HEIM	Phone #: (608)261-2461
Mailing Address: 1979 OAK VIEW DR	
City: VERONA	State: WI Zip Code: 53593
County: Dane	Co. Permit #: W04224
Notification #	Completed: 01-17-1991

1. Well Location

Town of SPRINGDALE

Fire # (if avail.)

Street Address or Road Name and Number: 9128 SHARPES CORNER

Subdivision Name | Lot # | Block #

Well Constructor (Business Name): RICKARD DEAN E	Lic. #: 481
Facility ID # (Public Wells)	
Well Plan Approval #	
Address: P O BOX 93 LINDEN WI 53553	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #
Specific Capacity: 1.3	

Latitude / Longitude in Decimal Degree (DD): 42.9574 °N -89.6941 °W

Method Code: GCD013

NW	NW	Section	Township	Range
or Govt Lot #		32	6 N	7 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?: NEW HOME

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	231
6	231	300

Upper Enlarged Drillhole / Lower Open Bedrock

Yes Rotary - Mud Circulation .....

Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	C			CLAY	Surface	10
	N			SANDSTONE	10	70
	H	N		CLAY-SANDSTONE	70	80
	L			MAGNESIA LIMESTONE	80	195
S	H			CLAY	195	197
B	L	N		BROKEN MAGNESIA LIMESTONE @ SOFT SANDSTO	197	220
	H			SHALESTONE	220	300

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK ST'D STEEL 18.97# P.E. WELDED ASTM A53.280 W.T. HKK	Surface	230
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

170 ft. below ground surface

10. Pump Test

Pumping level 185 ft. below surface

Pumping at 20 GP for 2 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method CEMENT GROUT

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	230	41

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
DR		01-29-1991
Drill Rig Operator	Lic or Reg #	Date Signed
DR		01-29-1991

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		150	Building Overhang		15
			Septic or Holding, or POWTS Tank		90

Comment:

Created On: 04-03-1991 Updated On: 12-11-2019 Review Status: