

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				CU686		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A																			
Property Owner JOHN MEIER						Phone #		1. Well Location				Fire # (if avail.)																	
Mailing Address 4351 CO HWY P						Town of CROSS PLAINS						Street Address or Road Name and Number 4351 CO HWY P																	
City CROSS PLAINS				State WI		Zip Code 53528																							
County Dane		Co. Permit # W04265		Notification #		Completed 02-11-1991		Subdivision Name				Lot #		Block #															
Well Constructor (Business Name) RICKARD DEAN E				Lic. # 481		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.0952 °N -89.6532 °W				Method Code GCD013															
Address P O BOX 93 LINDEN WI 53553				Well Plan Approval #		SE SW		Section 10		Township 7 N		Range 7 E																	
				Approval Date (mm-dd-yyyy)		or Govt Lot #		10		7 N		7 E																	
Hicap Permanent Well #		Common Well #		Specific Capacity 3		2. Well Type Replacement of previous unique well # constructed in																							
Reason for replaced or reconstructed well ? NO WATER		Construction Type Drilled																											
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes												Hicap Well ? No Hicap Property ? No Hicap Potable ?																	
4. Potential Contamination Sources - ON REVERSE SIDE																													
5. Drillhole Dimensions and Construction Method												8. Geology																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)													
8.75		Surface		105		Rotary - Mud Circulation <u>Yes</u> Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)		C		CLAY		Surface		15															
6		105		140						C S		CLAY-SAND		15		25													
										S H		SOFT SHALESTONE		25		100													
										H		SHALESTONE		100		140													
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		40 ft. below ground surface				12 in. above grade															
6		NEW BLACK ST'D STEEL 18.97# P.E. WELDED ASTM A53.280 W.T. HKK				Surface		104		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes															
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 45 ft. below surface																			
										Pumping at 15 GP for 2 Hrs. Pumping Method ?																			
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?																	
Method CEMENT GROUT												Filled & Sealed Well(s) as needed?																	
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		13. Constructor / Supervisory Driller														Lic #		Date Signed			
NEAT CEMENT				Surface		104		33																DR				02-18-1991	
												Drill Rig Operator				Lic or Reg #		Date Signed											
												DR								02-18-1991									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		350	Building Overhang		30
			Septic or Holding, or POWTS Tank		114

Comment:

Created On: 07-15-1991

Updated On: 12-11-2019

Review Status: