

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				CU687		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner LOLA SEIFERT						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address 8990 CO S						Town of CROSS PLAINS						Street Address or Road Name and Number 8990 CO S			
City MT HOREB				State WI		Zip Code 53572									
County Dane		Co. Permit # W04256		Notification #		Completed 01-19-1991		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) RICKARD DEAN E				Lic. # 481		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.0323 °N -89.6827 °W				Method Code GCD013	
Address P O BOX 93 LINDEN WI 53553				Well Plan Approval #				SE SE		Section 32		Township 7 N		Range 7 E	
				Approval Date (mm-dd-yyyy)				or Govt Lot #		32		7 N		7 E	
Hicap Permanent Well #				Common Well #		Specific Capacity 2				2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? NO WATER					
3. Well serves 1 # of Private, potable				Hicap Well ? No		Construction Type Drilled									
Heat Exchange ___ # of drillholes				Hicap Property ? No						Hicap Potable ?					
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock												
8.75 Surface 125			Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)												
6 125 200															
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		8. Geology					
6		NEW BLACK ST'D STEEL 18.97# P.E. WELDED ASTM A53.280 W.T. HKK				Surface		125							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Geology Codes Type, Caving/Noncaving, Color, Hardness, etc... From (ft.) To (ft.)					
7. Grout or Other Sealing Material															
Method CEMENT GROUT															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		9. Static Water Level 35 ft. below ground surface					
NEAT CEMENT				Surface		125		24							
10. Pump Test															
Pumping level 45 ft. below surface															
Pumping at 20 GP for 2 Hrs.															
Pumping Method ?															
11. Well Is															
12 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed? No															
PUMPMAN IS DOING IT															
13. Constructor / Supervisory Driller															
DR										Lic #		Date Signed			
DR										01-30-1991		13. Constructor / Supervisory Driller			
Drill Rig Operator										Lic or Reg #				Date Signed	
DR										01-30-1991					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		115	Building Overhang		30
			Septic or Holding, or POWTS Tank		95

Comment:

Created On: 07-12-1991

Updated On: 12-11-2019

Review Status: