Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CW205

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: TOM NOLEID	Phone #: (715)762-2387
Mailing Address: S 1ST AVE	
City: PARK FALLS	State: WI — Zip Code: 54552
County: Price	Co. Permit #: — Notification #: — Completed: 11-15-1990
Well Constructor (Business Name): DAVIS DAVID	Lic. #: 642 — Facility ID # (Public Wells):
Address: HCR3 BOX 42 PHILLIPS WI 54555	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.4

1. Well Location

Town of FIFIELD

Fire # (if avail.):

Street Address or Road Name and Number:

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): 45.88333 °N -90.41982 °W — Method Code: GPS008

or Govt Lot #	NW	NW	Section	Township	Range
			7	39 N	1 E

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	38

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		SAND	Surface	27
		S	G	SAND-GRAVEL-BOULDERS	27	38

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	BLK STEEL 18.97 LBS P/E SUMITOMO A53	Surface	38
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

12 ft. below ground surface

10. Pump Test

Pumping level 30 ft. below surface

Pumping at 8 GP for 4 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
DD		11-28-1989
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		88	Sewer - Building Sanitary		48
Shoreline/Pool		25	Septic or Holding, or POWTS Tank		67

Comment:

Created On: 02-27-1991 Updated On: 08-19-2022 Review Status: