

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				CW313		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner MARK LEFEBVRE						Phone # (414)866-2347		1. Well Location				Fire # (if avail.)							
Mailing Address RT 2 BOX 274A						Town of RED RIER						Street Address or Road Name and Number HWY 57							
City LUXEMBURG				State WI		Zip Code 54217													
County Kewaunee		Co. Permit #		Notification #		Completed 10-17-1989		Subdivision Name				Lot #		Block #					
Well Constructor (Business Name) HAROLD EUCLIDE				Lic. # 630		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.65181 °N -87.75262 °W				Method Code GCD001					
Address RT 1 2057 CNTY RD N BRUSSELS WI 54204-9801				Well Plan Approval #				NW SE		Section 7		Township 25 N		Range 23 E					
				Approval Date (mm-dd-yyyy)				or Govt Lot #		Township 25 N		Range 23 E							
Hicap Permanent Well #				Common Well #		Specific Capacity 0.1				2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled									
3. Well serves 1 # of				Hicap Well ? No															
Private, potable				Hicap Property ? No															
Heat Exchange ___ # of drillholes				Hicap Potable ?															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
8		Surface		160		Yes Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				C G		CLAY AND GRAVEL		Surface		158			
6		160		640						H		SHALE		160		425			
										L		DOLOMITE		425		630			
										N		SANDSTONE		630		640			
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		50 ft. below ground surface				14 in. above grade					
6		NEW BLACK STEEL PE WT 18.97 A53/API-5L				Surface		160		10. Pump Test Pumping level 160 ft. below surface Pumping at 10 GP for 3 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)											
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? No							
Method PRESSURE																			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement											
MUD				Surface		118		6 S											
CEMENT				118		158		6 S											
												13. Constructor / Supervisory Driller				Lic #		Date Signed	
												HE				02-02-1990			
												Drill Rig Operator				Lic or Reg #		Date Signed	
												WD				02-02-1990			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		8

Comment:

Created On: 03-14-1990

Updated On: 07-12-2021

Review Status: