Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CW313

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MARK LEFEBVRE			Phone #: (414)866-2347
Mailing Address: RT 2 BOX 274A			
City: LUXEMBURG	State: WI	Zip Code: 54217	
County: Kewaunee	Co. Permit #:	Notification #:	Completed: 10-17-1989

Well Constructor (Business Name): HAROLD EUCLIDE	Lic. #: 630	Facility ID # (Public Wells):	
Address: RT 1 2057 CNTY RD N BRUSSELS WI 54204-9801		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.1	

1. Well Location

Town of RED RIER

Fire # (if avail.):

Street Address or Road Name and Number: HWY 57

Subdivision Name:	Lot #:	Block #:

Latitude / Longitude in Decimal Degree (DD): 44.65181 °N -87.75262 °W				Method Code: GCD001
NW SE or Govt Lot #:	Section: 7	Township: 25 N	Range: 23 E	

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	160
6	160	640

Upper Enlarged Drillhole / Lower Open Bedrock

Yes Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C	G	CLAY AND GRAVEL	Surface	158
		H		SHALE	160	425
		L		DOLOMITE	425	630
		N		SANDSTONE	630	640

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK STEEL PE WT 18.97 A53/API-5L	Surface	160
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

50 ft. below ground surface

10. Pump Test

Pumping level 160 ft. below surface

Pumping at 10 GP for 3 Hrs.

Pumping Method ?

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method PRESSURE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
MUD	Surface	118	
CEMENT	118	158	6 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
HE		02-02-1990
Drill Rig Operator	Lic or Reg #	Date Signed
WD		02-02-1990

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		8

Comment:

Created On: 03-14-1990 Updated On: 07-12-2021 Review Status: