Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CW318

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: AUGUSTA DIONNE			Phone #: (414)856-6785
Mailing Address: 231 GAEDE AVE			
City: FORESTVILLE	State: WI	Zip Code: 54213	
County: Door	Co. Permit #:	Notification #:	Completed: 11-06-1989

1. Well Location

Village of FORESTVILLE

Fire # (if avail.):

Street Address or Road Name and Number: GAEDE AVE

Subdivision Name: | Lot #: | Block #:

Well Constructor (Business Name): EUCLIDE HAROLD A	Lic. #: 630	Facility ID # (Public Wells):	Latitude / Longitude in Decimal Degree (DD): 44.68799 °N -87.47986 °W
Address: RT 1 2057 COUNTY RD BRUSSELS WI 54204		Well Plan Approval #:	Method Code: GPS008
		Approval Date (mm-dd-yyyy):	NE NW Section: 32 Township: 26 N Range: 25 E
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.2	or Govt Lot #:

2. Well Type Replacement

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?:

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	58
8	58	170
6	170	220

Upper Enlarged Drillhole / Lower Open Bedrock

Yes — Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C	G	CLAY @ GRAVEL	Surface	58
		L		LIME ROCK	58	220

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK STEEL PE WT 18.97 A53/API-5L	Surface	170
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

4 ft. below ground surface

10. Pump Test

Pumping level 60 ft. below surface

Pumping at 10 GP for 3 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method PRESSURE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
MUD	Surface	6	
CEMENT	6	170	38

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
HE		02-02-1990
Drill Rig Operator	Lic or Reg #	Date Signed
WD		02-02-1990

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		6	Septic or Holding, or POWTS Tank		30

Comment:

Created On: 07-02-1990 Updated On: 07-12-2021 Review Status: