

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				CW322		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner STEVE HONOLD						Phone # (414)825-7010		1. Well Location				Fire # (if avail.)			
Mailing Address 9640 SCHOOL RD						Town of BRUSSELS						9640			
City BRUSSELS						State WI		Zip Code 54204				Street Address or Road Name and Number 9640 SCHOOL RD			
County		Co. Permit #		Notification #		Completed 12-14-1989		Subdivision Name				Lot # Block #			
Well Constructor (Business Name) EUCLIDE HAROLD A				Lic. # 630		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.7343 °N -87.6169 °W				Method Code GCD013	
Address RT 1 2057 COUNTY RD BRUSSELS WI 54204				Well Plan Approval #		SW SW Section Township Range or Govt Lot # 8 26 N 24 E		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled							
Approval Date (mm-dd-yyyy)				Hicap Permanent Well # Common Well # Specific Capacity 0.1		Hicap Well ? No Hicap Property ? No Hicap Potable ?									
Heat Exchange ___ # of drillholes				3. Well serves 1 # of Private, potable											
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock												
10 Surface 10			Rotary - Mud Circulation												
8 10 170			Yes Rotary - Air												
6 170 220			Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)												
8. Geology															
Dia. (in.)			Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.) To (ft.)				
6			C G				CLAY AND GRAVEL				Surface 10				
10			L				LIME ROCK				10 220				
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) To (ft.)		9. Static Water Level							
6		NEW BLACK STEEL PE WT 18.97 A53/API-5L				Surface 170		50 ft. below ground surface				11. Well Is			
Dia. (in.)		Screen type, material & slot size				From (ft.) To (ft.)		10. Pump Test				12 in. above grade			
10		10				10		Pumping level 120 ft. below surface Pumping at 10 GP for 3 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes			
7. Grout or Other Sealing Material															
Method PRESSURE															
Kind of Sealing Material		From (ft.) To (ft.)		# Sacks Cement											
MUD		Surface 6		40											
CEMENT		6 170		40											
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed? Yes															
13. Constructor / Supervisory Driller								Lic #		Date Signed					
HE								02-02-1990		Date Signed					
Drill Rig Operator								Lic or Reg #		Date Signed					
WD								02-02-1990		Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		26	Septic or Holding, or POWTS Tank		50

Comment:

Created On: 03-14-1990

Updated On: 12-03-2019

Review Status: