

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				CW325		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner WILLIE BERKHAHN Phone # (414)823-2012						1. Well Location				Fire # (if avail.)	
Mailing Address CTY A 6658						Town of JACKSONPORT				6658	
City EGG HARBOR State WI Zip Code 54209						Street Address or Road Name and Number CTY A					
County Door		Co. Permit #		Notification #		Completed 11-06-1989		Subdivision Name		Lot #	Block #
Well Constructor (Business Name) EUCLIDE HAROLD A				Lic. # 630	Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W		Method Code		
Address RT 1 2057 COUNTY RD BRUSSELS WI 54204				Well Plan Approval #		NE NE Section Township Range or Govt Lot # 15 29 N 27 E					
				Approval Date (mm-dd-yyyy)		2. Well Type New Well					
Hicap Permanent Well #				Common Well #		Specific Capacity 0.1		Reason for replaced or reconstructed well ?			
3. Well serves 1 # of Private, potable Heat Exchange ____ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled					
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)	From (ft.)	To (ft.)	Upper Enlarged Drillhole				Lower Open Bedrock				
10	Surface	18									
8	18	120	Rotary - Mud Circulation								
6	120	220	<u>Yes</u> Rotary - Air								
			Rotary - Air & Foam								
			Drill-Through Casing Hammer								
			Reverse Rotary								
			Cable-tool Bit ____ in. dia...								
			Dual Rotary								
			Temp. Outer Casing ____ in. dia								
			Removed? ____ depth ft. (If NO explain on back side)								
8. Geology											
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
		C	G	CLAY AND GRAVEL		Surface		18			
		L		LIME ROCK		18		220			
6. Casing, Liner, Screen											
Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)	To (ft.)					
6	NEW BLACK STEEL PE WT 18.97 A53/API-5L				Surface	120					
Dia. (in.)	Screen type, material & slot size				From (ft.)	To (ft.)					
7. Grout or Other Sealing Material											
Method PRESSURE											
Kind of Sealing Material		From (ft.)	To (ft.)	# Sacks Cement							
MUD		Surface	6								
CEMENT		6	120	32							
9. Static Water Level											
1 ft. below ground surface											
10. Pump Test											
Pumping level 100 ft. below surface											
Pumping at 10 GP for 3 Hrs.											
Pumping Method ?											
11. Well Is											
12 in. above grade											
Developed ? Yes											
Disinfected ? Yes											
Capped ? Yes											
12. Notified Owner of need to fill & seal ?											
Filled & Sealed Well(s) as needed? No											
13. Constructor / Supervisory Driller											
HE										Lic #	Date Signed
Drill Rig Operator										Lic or Reg #	Date Signed
WD											02-02-1990

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		18	Septic or Holding, or POWTS Tank		50

Comment:

Created On: 03-14-1990

Updated On: 07-11-2023

Review Status: