Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CX882

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: TERRY HOVE | Phone #:

Mailing Address: RR 2

City: MAIDEN ROCK | State: WI | Zip Code: 54750

County	Co. Permit #	Notification #	Completed
Pierce			11-20-1991

Well Constructor (Business Name): HOYER BROTHERS WELLDRILLING INC | Lic. #: 60 | Facility ID # (Public Wells):

Address: RT 1
BAY CITY WI 54723-9801

Well Plan Approval #:

Approval Date (mm-dd-yyyy):

Hicap Permanent Well # | Common Well # | Specific Capacity: 5

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Fire # (if avail.):

Town of EL PASO

Street Address or Road Name and Number:

Subdivision Name | Lot # | Block #

Latitude / Longitude in Decimal Degree (DD): °N °W | Method Code:

SE SE or Govt Lot #	Section	Township	Range
	33	26 N	16 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	60

Upper Enlarged Drillhole / Lower Open Bedrock

Yes Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		Y		SAND AND GRAVEL	Surface	21
	X	L	S	LAYERD LIME ROCK @ SAND	21	54
		L		LIMEROCK	54	60

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL PIPE NEW 19.45 A53 T@C KOREA	Surface	55
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method DROVE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE SLURRY	Surface	55	

9. Static Water Level
7 ft. below ground surface

10. Pump Test
Pumping level 9 ft. below surface
Pumping at 10 GP for 2 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
AH		11-23-1991
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
AH		11-23-1991

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		300	Building Overhang		12
Building Drain - Sanitary		30	Septic or Holding, or POWTS Tank		75

Comment:

Created On: 01-23-1992 Updated On: 01-23-1992 Review Status: