

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				CX940		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A													
Property Owner ISABELLE ROSS						Phone # (414)361-0662		1. Well Location				Fire # (if avail.)											
Mailing Address W 548 EXCHANGE ST						Town of AURORA						Street Address or Road Name and Number											
City BERLIN				State WI		Zip Code 54923																	
County Waushara		Co. Permit #		Notification #		Completed 04-16-1992		Subdivision Name			Lot #		Block #										
Well Constructor (Business Name) SALEFSKY, WAYNE W				Lic. # 567		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)			Method Code												
Address PO BOX 123 BERLIN WI 54923-0123				Well Plan Approval #		Approval Date (mm-dd-yyyy)		SE SE Section Township Range or Govt Lot # 35 18 N 13 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? HOME													
								Hicap Permanent Well #					Common Well #		Specific Capacity 1.4								
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled																	
4. Potential Contamination Sources - ON REVERSE SIDE																							
5. Drillhole Dimensions and Construction Method												8. Geology											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)							
6.625		Surface		122		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary <u>Yes</u> Cable-tool Bit 6in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)		S SAND Surface 5 G GRAVEL 5 33 C CLAY 33 61 G GRAVEL 61 115 S SAND 115 122		12 ft. below ground surface 10. Pump Test Pumping level 19 ft. below surface Pumping at 10 GP for 6 Hrs. Pumping Method ?		11. Well Is 12 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes											
6.625		T@C ASTM A53B 19.45#/FT V.S.P.CO. PR TESTED 1780P S I		Surface										119									
Dia. (in.)		Screen type, material & slot size		From (ft.)										To (ft.)									
6		3' 10 SLOT STAINLESS		119										122									
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly												From (ft.)		To (ft.)		12 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes					
6.625		T@C ASTM A53B 19.45#/FT V.S.P.CO. PR TESTED 1780P S I				Surface		119															
7. Grout or Other Sealing Material Method								12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? No REMOVED															
Method								13. Constructor / Supervisory Driller				Lic #		Date Signed									
								WS				Lic or Reg #		Date Signed									
								Drill Rig Operator				WS		05-12-1992									
								WS				05-12-1992											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	50	Building Overhang		15
			Septic or Holding, or POWTS Tank	>	50

Comment:

Created On: 06-01-1992

Updated On: 06-01-1992

Review Status: