Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CX940

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ISABELLE ROSS			Phone #: (414)361-0662
Mailing Address: W 548 EXCHANGE ST			
City: BERLIN	State: WI	Zip Code: 54923	
County: Waushara	Co. Permit #:	Notification #:	Completed: 04-16-1992

Well Constructor (Business Name): SALEFSKY, WAYNE W	Lic. #: 567	Facility ID # (Public Wells):	
Address: PO BOX 123 BERLIN WI 54923-0123		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 1.4	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of AURORA
Street Address or Road Name and Number

Fire # (if avail.)

Subdivision Name	Lot #	Block #	
Latitude / Longitude in Decimal Degree (DD): °N °W			Method Code
SE SE or Govt Lot #	Section: 35	Township: 18 N	Range: 13 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
HOME

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6.625	Surface	122

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 6in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
S	SAND	Surface	5
G	GRAVEL	5	33
C	CLAY	33	61
G	GRAVEL	61	115
S	SAND	115	122

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6.625	T@C ASTM A53B 19.45#/FT V.S.P.CO. PR TESTED 1780P S I	Surface	119
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	3' 10 SLOT STAINLESS	119	122

7. Grout or Other Sealing Material
Method

9. Static Water Level
12 ft. below ground surface

10. Pump Test
Pumping level 19 ft. below surface
Pumping at 10 GP for 6 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No
REMOVED

13. Constructor / Supervisory Driller	Lic #	Date Signed
WS		05-12-1992
Drill Rig Operator	Lic or Reg #	Date Signed
WS		05-12-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	50

Type	Qualifier	Distance
Building Overhang		15
Septic or Holding, or POWTS Tank	>	50

Comment:

Created On: 06-01-1992 Updated On: 06-01-1992 Review Status: