Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CY202

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BRUCE NELSON			Phone #: (715)483-1408
Mailing Address: BOX 89			
City: ST CROIX FALLS	State: WI	Zip Code: 54024	
County: Polk	Co. Permit #:	Notification #:	Completed: 10-09-1990

1. Well Location

Town of EUREKA

Fire # (if avail.):

Street Address or Road Name and Number:

Subdivision Name	Lot #	Block #

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
CHELL RONALD J AND RODNEY L	22	

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code:

Well Plan Approval #:

NE	NW	Section	Township	Range
or Govt Lot #		22	35 N	18 W

Address: ROUTE 3
FREDERIC WI 54837

Approval Date (mm-dd-yyyy):

2. Well Type New Well

of previous unique well #: constructed in

Hicap Permanent Well #	Common Well #	Specific Capacity
		1.5

Reason for replaced or reconstructed well ?

PRIVATE RESIDENCE

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	280

Upper Enlarged Drillhole

Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S	G	SAND AND GRAVEL	Surface	50
R		M	S	RED STILT SAND GRAVEL @ BOULDERS	50	150
	A	G		COARSE GRAVEL	150	200
		S	G	SAND AND GRAVEL	200	280

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW STD BLK P/E PIPE 18.97#/FT LTV ASTM A53	Surface	280
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

240 ft. below ground surface

10. Pump Test

Pumping level 250 ft. below surface

Pumping at 15 GP for 4 Hrs.

Pumping Method ?

11. Well Is

15 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
RC		10-31-1990
Drill Rig Operator	Lic or Reg #	Date Signed
RC		10-31-1990

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		80	Sewer - Building Sanitary		85
Shoreline/Pool		200	Septic or Holding, or POWTS Tank		100

Comment:

Created On: 03-26-1991 Updated On: 03-26-1991 Review Status: