Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CY324

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ROGER MIDDLETON			Phone #: (715)985-3348
Mailing Address: RT 2			
City: INDEPENDENCE	State: WI	Zip Code: 54747	
County: Trempealeau	Co. Permit #:	Notification #:	Completed: 01-15-1991

Well Constructor (Business Name): PELKE PLBG AND HTG INC	Lic. #: 131	Facility ID # (Public Wells):	
Address: 835 RIVERSIDE DR MONDOVI WI 54755		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 1.3	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of BURNSIDE
Fire # (if avail.)
Street Address or Road Name and Number

Subdivision Name	Lot #	Block #	
Latitude / Longitude in Decimal Degree (DD): °N °W			Method Code
SE SW or Govt Lot #	Section: 25	Township: 22 N	Range: 9 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
POINT IN BASEMENT WOULD N

Construction Type Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	5
6	5	85

Upper Enlarged Drillhole / Lower Open Bedrock

Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		I		TOP SOIL	Surface	1
T		S		BROWN SAND	1	4
G		S		GRAY SAND	4	18
G		S	M	GRAY SILTY SAND	18	75
	A	S		LIGHT GRAY COURSE SAND	75	85

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLK T/C PIPE ASTM A-53 GR. B (LTV STEEL)19.45LBS A F SEIDEMAN (NKK)	Surface	82
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	10 SLOT STAINLESS STEEL	82	85

7. Grout or Other Sealing Material
Method GRAVITY FED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILL SLURRY	Surface	5	

9. Static Water Level
12 ft. below ground surface

10. Pump Test
Pumping level 20 ft. below surface
Pumping at 10 GP for 3 Hrs.
Pumping Method ?

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No
STILL IN USE

13. Constructor / Supervisory Driller	Lic #	Date Signed
DF		01-18-1991
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
DF		01-18-1991

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		70	Sewer - Building Sanitary		35
Building Overhang		10	Septic or Holding, or POWTS Tank		40

Comment:

Created On: 04-04-1991 Updated On: 04-04-1991 Review Status: