

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				CY324		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner ROGER MIDDLETON						Phone # (715)985-3348		1. Well Location				Fire # (if avail.)					
Mailing Address RT 2						Town of BURNSIDE						Street Address or Road Name and Number					
City INDEPENDENCE				State WI		Zip Code 54747											
County Trempealeau		Co. Permit #		Notification #		Completed 01-15-1991		Subdivision Name			Lot #		Block #				
Well Constructor (Business Name) PELKE PLBG AND HTG INC				Lic. # 131		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W			Method Code						
Address 835 RIVERSIDE DR MONDOVI WI 54755				Well Plan Approval #		SE SW Section Township Range or Govt Lot # 25 22 N 9 W		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? POINT IN BASEMENT WOULD N									
Approval Date (mm-dd-yyyy)				Specific Capacity 1.3													
Hicap Permanent Well #		Common Well #		Hicap Well ? No		Hicap Property ? No		Construction Type Drilled									
Heat Exchange ___ # of drillholes				Hicap Potable ?													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method												8. Geology					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
10		Surface		5		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)		T S TOP SOIL Surface 1 G S BROWN SAND 1 4 G S M GRAY SAND 4 18 G S M GRAY SILTY SAND 18 75 A S LIGHT GRAY COURSE SAND 75 85		12 ft. below ground surface		14 in. above grade		Developed ? Yes Disinfected ? Yes Capped ? Yes			
6		5		85													
6. Casing, Liner, Screen						9. Static Water Level				11. Well Is							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		Pumping level 20 ft. below surface Pumping at 10 GP for 3 Hrs. Pumping Method ?							
6		NEW BLK T/C PIPE ASTM A-53 GR. B (LTV STEEL)19.45LBS A F SEIDEMAN (NKK)				Surface		82									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? No STILL IN USE							
4		10 SLOT STAINLESS STEEL				82		85									
7. Grout or Other Sealing Material										13. Constructor / Supervisory Driller				Lic #		Date Signed	
Method GRAVITY FED																	
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement											
DRILL SLURRY		Surface		5						DF 01-18-1991 Drill Rig Operator DF 01-18-1991							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		70	Sewer - Building Sanitary		35
Building Overhang		10	Septic or Holding, or POWTS Tank		40

Comment:

Created On: 04-04-1991

Updated On: 04-04-1991

Review Status: