Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CY325

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: TIM JOHNSON			Phone #: (715)983-2128
Mailing Address: RFD 1 BOX 64A			
City: WHITEHALL	State: WI	Zip Code: 54755	
County: Trempealeau	Co. Permit #:	Notification #:	Completed: 03-15-1991

1. Well Location

Town of PIGEON FALLS

Fire # (if avail.):

Street Address or Road Name and Number:

Subdivision Name: | Lot #: | Block #:

Well Constructor (Business Name): PELKE PLBG AND HTG INC	Lic. #: 131	Facility ID # (Public Wells):	Latitude / Longitude in Decimal Degree (DD): °N °W
Address: 835 RIVERSIDE DR MONDOVI WI 54755		Well Plan Approval #:	Method Code:
		Approval Date (mm-dd-yyyy):	SW SW / or Govt Lot #: Section: 3 Township: 22 N Range: 7 W
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 1.4	

2. Well Type Replacement

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?

OLD WELLS COULD NOT PRODU

3. Well serves # of EGG PLANT

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	5
6	5	52

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		I		TOP SOIL	Surface	2
	N	S		LIGHT BROWN FINE SAND	2	30
T		S		LIGHT BROWN SAND	30	52

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLK T/C PIPE ASTM A-53 GR B (LTV STEEL 19.45LBS AF SIEDMAN (NNK)	Surface	48
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	10 SLOT STAINLESS STEEL SCREEN	48	52

9. Static Water Level

23 ft. below ground surface

10. Pump Test

Pumping level 30 ft. below surface

Pumping at 10 GP for 4 Hrs.

Pumping Method ?

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method GRAVITY FED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILL SLURRY	Surface	5	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

STILL IN USE

13. Constructor / Supervisory Driller	Lic #	Date Signed
DSF		03-29-1991
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
DSF		03-29-1991

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		250	Animal Barn Pen		40
Building Overhang		40	Barn Gutter		55
Sewer - Building Sanitary		200	Septic or Holding, or POWTS Tank		225

Comment:

Created On: 07-12-1991 Updated On: 07-12-1991 Review Status: