

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				CY328		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner LAVERN BESEK						Phone # (715)985-3375		1. Well Location				Fire # (if avail.)					
Mailing Address RT 1 BOX 112						Town of ARCADIA						Street Address or Road Name and Number					
City ARCADIA				State WI		Zip Code 54612											
County Trempealeau		Co. Permit #		Notification #		Completed 03-21-1991		Subdivision Name			Lot #		Block #				
Well Constructor (Business Name) PELKE PLBG AND HTG INC				Lic. # 131		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code					
Address 835 RIVERSIDE DR MONDOVI WI 54755				Well Plan Approval #		NW NW Section Township Range or Govt Lot # 1 21 N 9 W		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? THE OLD 2" WELL PUMPS DRY									
Approval Date (mm-dd-yyyy)				Hicap Permanent Well #		Common Well #						Specific Capacity 1					
3. Well serves # of CATTLE				Hicap Well ? No		Construction Type Driven Point											
Private, potable				Hicap Property ? No													
Heat Exchange ___ # of drillholes				Hicap Potable ?													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method												8. Geology					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
10		Surface		5		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)		T S TOP SOIL Surface 2 E S M LIGHT BROWN SAND 2 22 N S M GREEN SILTY SAND 22 50 G S M FINE SILTY BROWN SAND 50 58 A S M GRAY SILTY SAND 58 75 A S GRAY COURSE SAND 75 84		35 ft. below ground surface		14 in. above grade		Developed ? Yes Disinfected ? Yes Capped ? Yes			
6. Casing, Liner, Screen						9. Static Water Level				11. Well Is							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		Pumping level 45 ft. below surface Pumping at 10 GP for 6 Hrs. Pumping Method ?							
6		NEW BLK T/C PIPE ASTM A-53 GR. B (LTV STEEL) 19.45LBS AF SIEDMANN (NNK)				Surface		81									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
4		10 SLOT STAINLESS STEEL SCREEN				81		84		12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? No STILL IN USE							
7. Grout or Other Sealing Material														13. Constructor / Supervisory Driller			
Method GRAVITY FED																	
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Lic #							
DRILL SLURY				Surface		5		5						Date Signed 03-29-1991			
Drill Rig Operator										Lic or Reg #							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		40	Animal Yard - Include Hutches		58
Animal Barn Pen		55	Barn Gutter		60

Comment:

Created On: 07-12-1991

Updated On: 07-12-1991

Review Status: