Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CY328

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: LAVERN BESEK	Phone #: (715)985-3375
Mailing Address: RT 1 BOX 112	
City: ARCADIA	State: WI — Zip Code: 54612
County: Trempealeau	Co. Permit #: — Notification #: — Completed: 03-21-1991
Well Constructor (Business Name): PELKE PLBG AND HTG INC	Lic. #: 131 — Facility ID # (Public Wells):
Address: 835 RIVERSIDE DR, MONDOVI WI 54755	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 1

1. Well Location

Town of ARCADIA

Fire # (if avail.):

Street Address or Road Name and Number:

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:

NW NW or Govt Lot # — Section: 1 — Township: 21 N — Range: 9 W

2. Well Type Replacement

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

THE OLD 2" WELL PUMPS DRY

Construction Type: Driven Point

3. Well serves # of CATTLE

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	5
6	5	84

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		I		TOP SOIL	Surface	2
T		S		LIGHT BROWN SAND	2	22
E		S	M	GREEN SILTY SAND	22	50
	N	S	M	FINE SILTY BROWN SAND	50	58
G		S	M	GRAY SILTY SAND	58	75
	A	S		GRAY COURSE SAND	75	84

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLK T/C PIPE ASTM A-53 GR. B (LTV STEEL) 19.45LBS AF SIEDMANN (NNK)	Surface	81
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	10 SLOT STAINLESS STEEL SCREEN	81	84

9. Static Water Level

35 ft. below ground surface

10. Pump Test

Pumping level 45 ft. below surface

Pumping at 10 GP for 6 Hrs.

Pumping Method ?

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method GRAVITY FED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILL SLURY	Surface	5	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

STILL IN USE

13. Constructor / Supervisory Driller	Lic #	Date Signed
		03-29-1991
Drill Rig Operator	Lic or Reg #	Date Signed
		03-29-1991

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		40	Animal Yard - Include Hutches		58
Animal Barn Pen		55	Barn Gutter		60

Comment:

Created On: 07-12-1991 Updated On: 07-12-1991 Review Status: