Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CY341

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: JIM EDLHUBER	Phone #: (414)544-0159
Mailing Address: S49 W28840 PARKE LN	
City: GENESEE	State: WI — Zip Code: 53186
County: Waukesha	Co. Permit #: — Notification #: — Completed: 12-06-1990
Well Constructor (Business Name): KRANZ ED	Lic. #: 340 — Facility ID # (Public Wells):
Address: 14325 W HAMPTON RD BROOKFIELD WI 53005	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #: — Common Well #: — Specific Capacity: 4	

1. Well Location

Town of GENESEE

Fire # (if avail.):

Street Address or Road Name and Number: S49 W28840 PARKE LN EAST

Subdivision Name	Lot #	Block #
	00009	

Latitude / Longitude in Decimal Degree (DD): 42.955 °N -88.3225 °W — Method Code: GCD013

NW or Govt Lot #	NW	Section	Township	Range
		25	6 N	18 E

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?: WATER FOR HOME

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	200
6	200	382

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
I	TOP SOIL	Surface	2
C	CLAY	2	10
L	LIMEROCK	10	382

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK STEEL P.E.-18.97# PER FT ASTM A-53 GR. BNKK	Surface	200
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

35 ft. below ground surface

10. Pump Test

Pumping level 40 ft. below surface

Pumping at 20 GP for 4 Hrs.

Pumping Method ?

11. Well Is

10 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method PLUG

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CEMENT	Surface	200	15

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
EK		12-29-1990
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Clearwater Sump		15	Septic or Holding, or POWTS Tank		70

Comment:

Created On: 04-02-1991 Updated On: 07-12-2019 Review Status: