Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CY347

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: HAROLD PETERS			Phone #: (608)849-4621
Mailing Address: W4276 CASTLE CT			
City: MAUSTON	State: WI	Zip Code: 53948	
County: Juneau	Co. Permit #:	Notification #:	Completed: 12-09-1990

1. Well Location

Town of GERMANTOWN

Fire # (if avail.):

Street Address or Road Name and Number:

Subdivision Name	Lot #	Block #
CASTLE ROCK GARDENS		

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
RUSH ROBERT L	181	

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code:

Well Plan Approval #:

Approval Date (mm-dd-yyyy):

Address: ROUTE 4 BOX 190
BLACK RIVER FALLS WI 54615

SE	SW	Section	Township	Range
or Govt Lot #		2	16 N	4 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

NEEDED WATER

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.1

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	82

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 6in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Q S	SAND, CAVING	Surface	82

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	BLACK PLAIN END-STEEL A53 18.97 WELDED SAWHILL,USA	Surface	79
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	STAINLESS STEEL W/NEOPRENE SEAL	79	82

9. Static Water Level

18 ft. below ground surface

10. Pump Test

Pumping level 70 ft. below surface

Pumping at 6 GP for 6 Hrs.

Pumping Method ?

11. Well Is

10 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
JAR		12-28-1990
Drill Rig Operator	Lic or Reg #	Date Signed
JAR		12-28-1990

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		68
Building Overhang		9

Type	Qualifier	Distance
Sewer - Building Sanitary		40
Septic or Holding, or POWTS Tank		53

Comment:

Created On: 07-17-1991 Updated On: 07-17-1991 Review Status: