

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				CY348		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner RICHARD W VERNON						Phone # (715)284-1647		1. Well Location				Fire # (if avail.)			
Mailing Address PO BOX 423						Town of BROCKWAY						Street Address or Road Name and Number W CASTLE MOUND RD			
City BLACK RIVER FALLS			State WI		Zip Code 54615			Subdivision Name						Lot #	
County Jackson		Co. Permit #		Notification #		Completed 12-06-1990		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code			
Well Constructor (Business Name) RUSH ROBERT L				Lic. # 181		Facility ID # (Public Wells)		NW		Section 29		Township 21 N		Range 3 W	
Address ROUTE 4 BOX 190 BLACK RIVER FALLS WI 54615						Well Plan Approval #		2. Well Type New Well							
Approval Date (mm-dd-yyyy)						of previous unique well # constructed in									
Hicap Permanent Well #			Common Well #			Specific Capacity 1.6		Reason for replaced or reconstructed well ? NEEDED WATER							
3. Well serves 1 # of						Hicap Well ? No		Construction Type Drilled							
Private, potable						Hicap Property ? No									
Heat Exchange ____ # of drillholes						Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		50		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary <u>Yes</u> Cable-tool Bit 6in. dia... Dual Rotary Temp. Outer Casing ____ in. dia Removed? ____ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
Q S I				SAND SOIL, CAVING				Surface		33					
N				SAND ROCK				33		50					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		BLACK PLAIN END-STEEL A 53 18.97 WELDED SAWHILL, USA				Surface		35							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material Method															
9. Static Water Level 23 ft. below ground surface															
10. Pump Test Pumping level 28 ft. below surface Pumping at 8 GP for 6 Hrs. Pumping Method ?															
11. Well Is 10 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes															
12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?															
13. Constructor / Supervisory Driller								Lic #		Date Signed					
RLR										12-29-1990					
Drill Rig Operator								Lic or Reg #		Date Signed					
RLR										12-29-1990					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		53	Sewer - Building Sanitary		25
Building Overhang		13	Septic or Holding, or POWTS Tank		39

Comment:

Created On: 07-17-1991

Updated On: 07-17-1991

Review Status: