

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				CY374		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner PETER WRIGHT						Phone # (414)731-7850		1. Well Location				Fire # (if avail.)					
Mailing Address 416 TRILLIUM CT						Town of GREENVILLE						Street Address or Road Name and Number 416 TRILLIUM CT					
City APPLETON				State WI		Zip Code 54915											
County Outagamie		Co. Permit #		Notification #		Completed 02-06-1991		Subdivision Name			Lot #		Block #				
Well Constructor (Business Name) WILLEMS JR LEONARD				Lic. # 451		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W			Method Code						
Address ROUTE 1 GREENLEAF WI 54126				Well Plan Approval #		NE SE Section Township Range or Govt Lot # 7 21 N 19 E		2. Well Type New Well YR903 replaces this well of previous unique well # constructed in									
				Approval Date (mm-dd-yyyy)													
Hicap Permanent Well #		Common Well #		Specific Capacity 1.3		Reason for replaced or reconstructed well ? NEW HOME											
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled											
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method												8. Geology					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
10		Surface		65		Yes Rotary - Mud Circulation Yes Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)		C CLAY G GRAVEL L LIMESTONE		Surface 45 45 65 65 142		45		142			
6. Casing, Liner, Screen						9. Static Water Level				11. Well Is							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		80 ft. below ground surface				12 in. above grade			
6		ASTM A-53 GR. B NEWPORT STEEL WELDED JOINT WT.18.97 PER FT.				Surface		66		10. Pump Test Pumping level 95 ft. below surface Pumping at 20 GP for 4 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
7. Grout or Other Sealing Material						12. Notified Owner of need to fill & seal ?											
Method						Filled & Sealed Well(s) as needed?											
Kind of Sealing Material		From (ft.)		To (ft.)												# Sacks Cement	
DRILLING MUD		Surface		65													
						13. Constructor / Supervisory Driller				Lic #		Date Signed					
						LJW						02-12-1991					
						Drill Rig Operator				Lic or Reg #		Date Signed					
						TO						02-12-1991					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Building Overhang		12
			Septic or Holding, or POWTS Tank		50

Comment:

Abandonment Type	Abandonment Date	Procedure	Reason
	11/18/2016	3/8" BARIOD HOLE PLUG 0-136' 39 SACKS USED	LOW YIELDING WELL

Created On: 07-17-1991

Updated On: 11-28-2016

Review Status: