Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CY374

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: PETER WRIGHT	Phone #: (414)731-7850
Mailing Address: 416 TRILLIUM CT	
City: APPLETON	State: WI — Zip Code: 54915
County: Outagamie	Co. Permit #: — Notification #: — Completed: 02-06-1991
Well Constructor (Business Name): WILLEMS JR LEONARD	Lic. #: 451 — Facility ID # (Public Wells):
Address: ROUTE 1 GREENLEAF WI 54126	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 1.3

1. Well Location

Town of GREENVILLE

Fire # (if avail.):

Street Address or Road Name and Number: 416 TRILLIUM CT

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:

NE	SE	Section	Township	Range
or Govt Lot #		7	21 N	19 E

2. Well Type New Well — YR903 replaces this well of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

NEW HOME

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	65
6	65	142

Upper Enlarged Drillhole — Lower Open Bedrock

Yes Rotary - Mud Circulation .....

Yes Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
C	CLAY	Surface	45
G	GRAVEL	45	65
L	LIMESTONE	65	142

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A-53 GR. B NEWPORT STEEL WELDED JOINT WT.18.97 PER FT.	Surface	66
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

80 ft. below ground surface

10. Pump Test

Pumping level 95 ft. below surface

Pumping at 20 GP for 4 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILLING MUD	Surface	65	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
LJW		02-12-1991
Drill Rig Operator	Lic or Reg #	Date Signed
TO		02-12-1991

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Building Overhang		12
			Septic or Holding, or POWTS Tank		50

Comment:

Abandonment Type	Abandonment Date	Procedure	Reason
	11/18/2016	3/8" BARIOD HOLE PLUG 0-136' 39 SACKS USED	LOW YIELDING WELL

Created On: 07-17-1991 Updated On: 11-28-2016 Review Status: