Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CY375

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: CHRIS VAN DE HEY	Phone #
Mailing Address: 4065 OLD CAR CT	
City: DE PERE	State: WI — Zip Code: 54115
County: Brown	Co. Permit #	Notification #	Completed: 02-08-1991

1. Well Location

Fire # (if avail.)

Town of WRIGHTSTOWN

Street Address or Road Name and Number: 4065 OLD CAR CT

Subdivision Name | Lot # | Block #

Well Constructor (Business Name): WILLEMS JR LEONARD	Lic. #: 451	Facility ID # (Public Wells)	Latitude / Longitude in Decimal Degree (DD): 44.3465 °N -88.1497 °W — Method Code: GCD013
		Well Plan Approval #	NW SW — Section: 25 — Township: 22 N — Range: 19 E — or Govt Lot #
Address: ROUTE 1 GREENLEAF WI 54126		Approval Date (mm-dd-yyyy)	**2. Well Type** New Well
			of previous unique well # — constructed in
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.6	Reason for replaced or reconstructed well ?: NEW HOME
3. Well serves 1 # of Private,potable Heat Exchange____# of drillholes		Hicap Well ? No Hicap Property ? No Hicap Potable ?	Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	122
6	122	324

Upper Enlarged Drillhole — Lower Open Bedrock

Yes Rotary - Mud Circulation .....
Yes Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
C	CLAY	Surface	90
G	GRAVEL, BOULDERS	90	122
L	LIMESTONE	122	324

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A-53 GR. B NEWPORT STEEL WELDED JOINT WT.18.97 PER FT.	Surface	123
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

60 ft. below ground surface

10. Pump Test

Pumping level 95 ft. below surface

Pumping at 20 GP for 4 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILLING MUD	Surface	122	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
LJW		02-12-1991
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
TW		02-12-1991

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		150	Building Overhang		12
			Septic or Holding, or POWTS Tank		50

Comment:

Created On: 07-17-1991 Updated On: 11-21-2019 Review Status: