

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				CZ506		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A															
Property Owner BERNARD RITCHIE						Phone # (414)982-4604		1. Well Location				Fire # (if avail.)													
Mailing Address RT 3 RITCHIE LN						Town of LEBANON						Street Address or Road Name and Number LARRY RD													
City NEW LONDON				State WI		Zip Code 54961																			
County Waupaca		Co. Permit #		Notification #		Completed 04-14-1992		Subdivision Name			Lot #		Block #												
Well Constructor (Business Name) JOHNSON, MICHAEL				Lic. # 545		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W			Method Code														
Address RT 1 BOX 14A OGDENSBURG WI 54962-9704				Well Plan Approval #		NW SW		Section 33		Township 23 N		Range 14 E													
				Approval Date (mm-dd-yyyy)		or Govt Lot #																			
Hicap Permanent Well #		Common Well #		Specific Capacity 2.7		2. Well Type New Well																			
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No		of previous unique well # _____ constructed in _____ Reason for replaced or reconstructed well ? NEW HOUSE																	
						Hicap Property ? No																			
4. Potential Contamination Sources - ON REVERSE SIDE						Hicap Potable ?		Construction Type Drilled																	
5. Drillhole Dimensions and Construction Method												8. Geology													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)									
10		Surface		20		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary <u>Yes</u> Cable-tool Bit 10in. dia... Dual Rotary <u>Yes</u> Temp. Outer Casing 10in. dia <u>Yes</u> Removed? ___depth ft. (If NO explain on back side)				G		Z		G		GREY CLAY GRAVEL @ BOULDERS		Surface		70					
6		20		84								Y						SAND @ GRAVEL		70		73			
												H		C		G		HARD GREY CLAY GRAVEL		73		75			
														Y						SAND @ GRAVEL		75		84	
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is									
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		60 ft. below ground surface				15 in. above grade											
6		6" NEW ASTM 589 SAWHILL T@C R@D 19.45LB FOOT				Surface		80		10. Pump Test Pumping level 66 ft. below surface Pumping at 16 GP for 24 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes											
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)																	
6		JOHNSON 10 SLOT STAINLESS STEEL K PACKER				80		84		12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?															
7. Grout or Other Sealing Material																									
Method																									
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement																	
CLAY SLURRY				Surface		20				13. Constructor / Supervisory Driller															
								Lic #				Date Signed													
MJ												05-12-1992													
Drill Rig Operator								Lic or Reg #				Date Signed													
MJ												05-12-1992													

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		25

Comment:

Created On: 06-01-1992

Updated On: 06-01-1992

Review Status: