Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CZ506

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BERNARD RITCHIE	Phone #: (414)982-4604
Mailing Address: RT 3 RITCHIE LN	
City: NEW LONDON	State: WI — Zip Code: 54961
County: Waupaca	Co. Permit #: — Notification #: — Completed: 04-14-1992
Well Constructor (Business Name): JOHNSON, MICHAEL	Lic. #: 545 — Facility ID # (Public Wells):
Address: RT 1 BOX 14A OGDENSBURG WI 54962-9704	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 2.7

1. Well Location

Town of LEBANON

Fire # (if avail.):

Street Address or Road Name and Number: LARRY RD

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:

NW SW or Govt Lot #: — Section: 33 — Township: 23 N — Range: 14 E

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: NEW HOUSE

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	20
6	20	84

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 10in. dia...
- Dual Rotary .....
- Yes — Temp. Outer Casing 10in. dia
- Yes — Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
G		Z	G	GREY CLAY GRAVEL @ BOULDERS	Surface	70
		Y		SAND @ GRAVEL	70	73
	H	C	G	HARD GREY CLAY GRAVEL	73	75
		Y		SAND @ GRAVEL	75	84

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	6" NEW ASTM 589 SAWHILL T@C R@D 19.45LB FOOT	Surface	80
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
6	JOHNSON 10 SLOT STAINLESS STEEL K PACKER	80	84

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CLAY SLURRY	Surface	20	

9. Static Water Level

60 ft. below ground surface

10. Pump Test

Pumping level 66 ft. below surface

Pumping at 16 GP for 24 Hrs.

Pumping Method ?

11. Well Is

15 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
MJ		05-12-1992
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
MJ		05-12-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		25

Comment:

Created On: 06-01-1992 Updated On: 06-01-1992 Review Status: