Well Construction Report
WISCONSIN UNIQUE WELL NUMBER DA142

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: RON AND JAN WOLF			Phone #
Mailing Address: 2871 SCENIC DR			
City: OSHKOSH	State: WI	Zip Code: 54904	
County: Winnebago	Co. Permit #	Notification #	Completed: 12-20-1990

Well Constructor (Business Name): TIPLER WELL AND PUMP	Lic #: 55	Facility ID # (Public Wells)	
Address: 15260 LONG ST P O BO LAKEWOOD WI 54138		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 3	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of ALGOMA

Fire # (if avail.)

Street Address or Road Name and Number: 2871 SCENIC DR

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
44.0271 °N	-88.6055 °W			GCD013
NE NE or Govt Lot #	Section: 17	Township: 18 N	Range: 16 E	

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NEW HOME

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	41
6	41	57

Upper Enlarged Drillhole / Lower Open Bedrock

Yes Rotary - Mud Circulation .....
Yes Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C		CLAY	Surface	10
		C	G	CLAY BOULDERS	10	15
		C		CLAY	15	25
		L		LIMESTONE	25	57

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A-53 GR B NEWPORT STEEL WELDED JOINTS WT18.97 PER FT	Surface	42
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
30 ft. below ground surface

10. Pump Test
Pumping level 40 ft. below surface
Pumping at 30 GP for 4 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method PRESSURE GROUT

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CEMENT	Surface	41	5

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
AT		01-08-1991
Drill Rig Operator	Lic or Reg #	Date Signed
AT		01-08-1991

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		12	Collector Sewer - San or Storm		100

Comment:

Created On: 04-03-1991 Updated On: 10-18-2019 Review Status: