

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				DA142		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner RON AND JAN WOLF						Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address 2871 SCENIC DR								Town of ALGOMA					
City OSHKOSH						State WI		Zip Code 54904					
County Winnebago		Co. Permit #		Notification #		Completed 12-20-1990		Subdivision Name				Lot #	
								Block #					
Well Constructor (Business Name) TIPLER WELL AND PUMP				Lic. # 55		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.0271 °N -88.6055 °W			
						Well Plan Approval #				Method Code GCD013			
Address 15260 LONG ST P O BO LAKEWOOD WI 54138						Approval Date (mm-dd-yyyy)				NE NE Section Township Range or Govt Lot # 17 18 N 16 E			
Hicap Permanent Well #				Common Well #		Specific Capacity 3				2. Well Type New Well			
										of previous unique well # constructed in			
Reason for replaced or reconstructed well ? NEW HOME													
3. Well serves 1 # of				Hicap Well ? No									
Private, potable				Hicap Property ? No									
Heat Exchange ____ # of drillholes				Hicap Potable ?						Construction Type Drilled			
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole Lower Open Bedrock							
10		Surface		41		Yes Rotary - Mud Circulation							
6		41		57		Yes Rotary - Air							
						Rotary - Air & Foam							
						Drill-Through Casing Hammer							
						Reverse Rotary							
						Cable-tool Bit ____ in. dia...							
						Dual Rotary							
						Temp. Outer Casing ____ in. dia							
						Removed? ____ depth ft. (If NO explain on back side)							
8. Geology													
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
C		CLAY				Surface		10					
C G		CLAY BOULDERS				10		15					
C		CLAY				15		25					
L		LIMESTONE				25		57					
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
6		ASTM A-53 GR B NEWPORT STEEL WELDED JOINTS WT18.97 PER FT				Surface		42					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
7. Grout or Other Sealing Material													
Method PRESSURE GROUT													
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement							
CEMENT		Surface		41		5							
9. Static Water Level													
30 ft. below ground surface													
10. Pump Test													
Pumping level 40 ft. below surface													
Pumping at 30 GP for 4 Hrs.													
Pumping Method ?													
11. Well Is													
12 in. above grade													
Developed ? Yes													
Disinfected ? Yes													
Capped ? Yes													
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed?													
13. Constructor / Supervisory Driller													
Lic #		Date Signed											
AT		01-08-1991											
Drill Rig Operator													
Lic or Reg #		Date Signed											
AT		01-08-1991											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		12	Collector Sewer - San or Storm		100

Comment:

Created On: 04-03-1991

Updated On: 10-18-2019

Review Status: