Well Construction Report
WISCONSIN UNIQUE WELL NUMBER DA148

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ROBERT SHIMER	Phone #: (414)794-1925
Mailing Address: 1516 CRYSTAL SPGS RD	
City: TWO RIVERS	State: WI Zip Code: 54241
County: Manitowoc	Co. Permit #:
Notification #	Completed: 01-15-1991
Well Constructor (Business Name): TIPLER WELL AND PUMP	Lic. #: 55
Facility ID # (Public Wells)	
Well Plan Approval #	
Address: 15260 LONG ST P O BO LAKEWOOD WI 54138	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #
Specific Capacity: 3	

1. Well Location

Town of TWO RIVERS

Fire # (if avail.)

Street Address or Road Name and Number: 1516 CRYSTAL SPRING RD

Subdivision Name	Lot #	Block #
Latitude / Longitude in Decimal Degree (DD): 44.1866 °N -87.6271 °W	Method Code: GCD013	

NW	SE	Section	Township	Range
or Govt Lot #		21	20 N	24 E

2. Well Type Replacement

of previous unique well # constructed in

Reason for replaced or reconstructed well ?: REPLACED ILLEGAL WELL IN

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	90
6	90	94

Upper Enlarged Drillhole / Lower Open Bedrock

Yes Rotary - Mud Circulation .....

Yes Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
S	SAND	Surface	20
C	CLAY	20	50
G	GRAVEL BOULDERS	50	60
C	CLAY	60	80
P	HARD PAN	80	90
L	LIMESTONE	90	94

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A53 GR B NEWPORT STEEL WELDED JT WT 18.97PER FT	Surface	91
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

20 ft. below ground surface

10. Pump Test

Pumping level 30 ft. below surface

Pumping at 30 GP for 4 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILLING MUD	Surface	90	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

NOTIFIED TO ABANDON

13. Constructor / Supervisory Driller	Lic #	Date Signed
AT		01-18-1991
Drill Rig Operator	Lic or Reg #	Date Signed
AT		01-18-1991

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		55

Type	Qualifier	Distance
Building Overhang		8
Septic or Holding, or POWTS Tank		30

Comment:

Created On: 04-03-1991 Updated On: 10-15-2019 Review Status: