

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				DB328		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner EDWIN KOEFERL					Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address 2908 COUNTY LINE RD					Town of RICHFIELD		Street Address or Road Name and Number							
City COLGATE					State WI		Zip Code 53017							
County Washington		Co. Permit # W05994		Notification #		Completed 05-26-1992		Subdivision Name			Lot #		Block #	
Well Constructor (Business Name) GIBOUR, DARYL BUTCH				Lic. # 17		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)			Method Code			
Address 7482 CIRCLE DR LANNON WI 53046-9700				Well Plan Approval #		SE SE Section Township Range or Govt Lot # 36 9 N 19 E		2. Well Type Replacement						
Hicap Permanent Well #				Common Well #		Specific Capacity 0.1		Reason for replaced or reconstructed well ? CONTAMINATED						
3. Well serves 1 # of Private, potable				Hicap Well ? No		Hicap Property ? No		Construction Type Drilled						
Heat Exchange ___ # of drillholes				Hicap Potable ?										
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock											
12 Surface 23			Rotary - Mud Circulation											
10 23 206			<u>Yes</u> Rotary - Air											
6 206 365			Rotary - Air & Foam											
			Drill-Through Casing Hammer											
			Reverse Rotary											
			Cable-tool Bit ___ in. dia...											
			Dual Rotary											
			<u>Yes</u> Temp. Outer Casing 10in. dia											
			<u>Yes</u> Removed? ___ depth ft. (If NO explain on back side)											
8. Geology														
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.)		To (ft.)			
Z			CLAY @ GRAVEL						Surface		23			
L			LIMESTONE						23		345			
H L			INTERMITTENT SHALE @ LIMESTONE						345		365			
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)						
6		ASTM A-53 P.E. SAWHILL				Surface		206						
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)						
7. Grout or Other Sealing Material														
Method GROUT PUMP														
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement						
NEAT CEMENT GROUT				Surface		206		171.5						
9. Static Water Level														
63 ft. below ground surface														
10. Pump Test														
Pumping level 135 ft. below surface														
Pumping at 10 GP for 3 Hrs.														
Pumping Method ?														
11. Well Is														
12 in. above grade														
Developed ? Yes														
Disinfected ? Yes														
Capped ? Yes														
12. Notified Owner of need to fill & seal ?														
Filled & Sealed Well(s) as needed? Yes														
13. Constructor / Supervisory Driller														
DG								Lic #		Date Signed				
DG								05-26-1992		05-26-1992				
Drill Rig Operator								Lic or Reg #		Date Signed				
DG														

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		95	Buried Petroleum Tank	>	300
Building Overhang		20	Animal Yard - Include Hutches		300
Clearwater Sump		25	Septic or Holding, or POWTS Tank		50

Comment:

Created On: 06-24-1992

Updated On: 06-24-1992

Review Status: