Well Construction Report
WISCONSIN UNIQUE WELL NUMBER DB328

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: EDWIN KOEFERL	Phone #
Mailing Address: 2908 COUNTY LINE RD	
City: COLGATE	State: WI — Zip Code: 53017
County: Washington	Co. Permit #: W05994 — Notification #: — Completed: 05-26-1992
Well Constructor (Business Name): GIBOUR, DARYL BUTCH	Lic. #: 17 — Facility ID # (Public Wells):
Address: 7482 CIRCLE DR, LANNON WI 53046-9700	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.1

1. Well Location

Town of RICHFIELD

Fire # (if avail.):

Street Address or Road Name and Number: 2908 COUNTY LINE RD

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:

SE	SE	Section	Township	Range
or Govt Lot #		36	9 N	19 E

2. Well Type Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: CONTAMINATED

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
12	Surface	23
10	23	206
6	206	365

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes — Temp. Outer Casing 10in. dia
- Yes — Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		Z		CLAY @ GRAVEL	Surface	23
		L		LIMESTONE	23	345
		H	L	INTERMITTENT SHALE @ LIMESTONE	345	365

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A-53 P.E. SAWHILL	Surface	206
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method: GROUT PUMP

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	206	171.5

9. Static Water Level

63 ft. below ground surface

10. Pump Test

Pumping level 135 ft. below surface

Pumping at 10 GP for 3 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
DG		05-26-1992
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
DG		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		95
Building Overhang		20
Clearwater Sump		25
Buried Petroleum Tank	>	300
Animal Yard - Include Hutches		300
Septic or Holding, or POWTS Tank		50

Comment:

Created On: 06-24-1992 Updated On: 06-24-1992 Review Status: