

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				DB330		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner MICHAEL LOSIK						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address 317 LOFTWOOD TERR						Town of RICHFIELD						Street Address or Road Name and Number 317 LOFTWOOD TERR							
City COLGATE				State WI		Zip Code 53017													
County Washington		Co. Permit # W06016		Notification #		Completed 06-09-1992		Subdivision Name WILLOWGATE			Lot # 00008		Block #						
Well Constructor (Business Name) GIBOUR, DARYL BUTCH				Lic. # 17		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W			Method Code								
Address 7482 CIRCLE DR LANNON WI 53046-9700				Well Plan Approval #		SE NW		Section 36		Township 9 N		Range 19 E							
				Approval Date (mm-dd-yyyy)		or Govt Lot #		Range		Range									
Hicap Permanent Well #		Common Well #		Specific Capacity		2. Well Type New Well													
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No		Reason for replaced or reconstructed well ? NEW RESIDENCE											
						Hicap Property ? No													
4. Potential Contamination Sources - ON REVERSE SIDE						Hicap Potable ?		Construction Type Drilled											
						5. Drillhole Dimensions and Construction Method						8. Geology							
Dia. (in.) 10		From (ft.) Surface		To (ft.) 20		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
6		20		265		Rotary - Mud Circulation		Rotary - Air		Z CLAY @ GRAVEL		Surface		21					
Yes		Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)		Y SAND @ GRAVEL		C CLAY		Z CLAY @ GRAVEL		78		114		L LIMESTONE		114		265	
6. Casing, Liner, Screen						9. Static Water Level				11. Well Is									
Dia. (in.) 6		Material, Weight, Specification ASTM-A-53-B P.E. SAWHILL				From (ft.) Surface		To (ft.) 114		76 ft. below ground surface				12 in. above grade					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test				Developed ? Yes					
7. Grout or Other Sealing Material Method Kind of Sealing Material From (ft.) To (ft.) # Sacks Cement DRILL CUTTINGS Surface 20						Pumping level 76 ft. below surface				Disinfected ? Yes Capped ? Yes									
						Pumping at 10 GP for 3 Hrs.													
12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?						13. Constructor / Supervisory Driller				Lic #		Date Signed							
						BG				06-10-1992									
						Drill Rig Operator				Lic or Reg #		Date Signed							
						_____				_____		_____							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Clearwater Sump		20
Building Overhang		15	Wastewater Sump		60
			Septic or Holding, or POWTS Tank		80

Comment:

Created On: 06-24-1992

Updated On: 06-24-1992

Review Status: