Well Construction Report
WISCONSIN UNIQUE WELL NUMBER DB330

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MICHAEL LOSIK			Phone #
Mailing Address: 317 LOFTWOOD TERR			
City: COLGATE	State: WI	Zip Code: 53017	
County: Washington	Co. Permit #: W06016	Notification #	Completed: 06-09-1992

Well Constructor (Business Name): GIBOUR, DARYL BUTCH	Lic. #: 17	Facility ID # (Public Wells)	
Address: 7482 CIRCLE DR LANNON WI 53046-9700		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity	

1. Well Location

Town of RICHFIELD

Fire # (if avail.)

Street Address or Road Name and Number: 317 LOFTWOOD TERR

Subdivision Name: WILLOWGATE	Lot #: 00008	Block #

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code

SE NW or Govt Lot #	Section: 36	Township: 9 N	Range: 19 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?: NEW RESIDENCE

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	20
6	20	265

Upper Enlarged Drillhole / Lower Open Bedrock

Yes — Rotary - Air .....

Rotary - Mud Circulation .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Z	CLAY @ GRAVEL	Surface	21
Y	SAND @ GRAVEL	21	34
C	CLAY	34	78
Z	CLAY @ GRAVEL	78	114
L	LIMESTONE	114	265

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM-A-53-B P.E. SAWHILL	Surface	114
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

76 ft. below ground surface

10. Pump Test

Pumping level 76 ft. below surface

Pumping at 10 GP for 3 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILL CUTTINGS	Surface	20	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
BG		06-10-1992
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100
Building Overhang		15

Type	Qualifier	Distance
Clearwater Sump		20
Wastewater Sump		60
Septic or Holding, or POWTS Tank		80

Comment:

Created On: 06-24-1992 Updated On: 06-24-1992 Review Status: